

- E • **elearning** . Labourers are found for carrying and disposals of... Wed, Jul 1, 2020 at 12:51 PM ★
- W • **werner.fourie@au.sedgwick.com** ...be.info@dmirs.wa.gov.au" <be.info@dmirs.wa.gov.au> cc... Wed, Jul 1, 2020 at 1:54 PM ★
- BI • **BE Info** ...WorkSafe: 1300 30 78 77 or +61 8 6251 2200 | wscallcentre@dmirs.wa.gov.au... Wed, Jul 1, 2020 at 4:24 PM ★
- E • **elearning** . ...BE Info <be.info@dmirs.wa.gov.au> wrote: Dear Engr,... Thu, Jul 2, 2020 at 10:10 PM ★
- E • **elearning** . ...BE Info <be.info@dmirs.wa.gov.au> wrote: Dear Engr,... Thu, Jul 2, 2020 at 10:20 PM ★
- BI • **BE Info** <be.info@dmirs.wa.gov.au> Fri, Jul 3, 2020 at 3:39 PM ★  
 To: elearning .

Dear Afsaneh

Thank you for contacting Building and Energy at the Department of Mines, Industry Regulation and Safety regarding your follow up enquiry.

The retaining wall needs to be fit for purpose. AS 4678-2002 Earth Retaining Structures specifies the design criteria for retaining walls. A retaining wall built under a Building Permit will generally require a engineers compliance certificate.

However your first part of the query needs to be verified with our building inspector as it requires some technical explanation. I have forwarded your email.

Appreciate your patience.



Jessica Joseph| Customer Contact Officer  
 Safety, Building and Energy Contact Centre | Customer Information Directorate  
 Department of Mines, Industry Regulation and Safety  
 Level 1, Mason Bird Building, 303 Sevenoaks Street, CANNINGTON WA 6107  
 Locked Bag 100, EAST PERTH, WA 6892  
 Building & Energy: 1300 489 099 or +61 8 6251 2917 | [be.info@dmirs.wa.gov.au](mailto:be.info@dmirs.wa.gov.au)  
 WorkSafe: 1300 30 78 77 or +61 8 6251 2200 | [wscallcentre@dmirs.wa.gov.au](mailto:wscallcentre@dmirs.wa.gov.au)  
[www.dmirs.wa.gov.au](http://www.dmirs.wa.gov.au)



▼ Hide original message

**From:** elearning . <elearning@ewindfly.net>  
**Sent:** Thursday, 2 July 2020 10:20 PM  
**To:** BE Info <be.info@dmirs.wa.gov.au>  
**Subject:** Re: SGW202579068

Build... Thanks Werner, I did your neighr..

Please refer to the [Magistrates Cou...](#)

...41 PM GMT+8, BE Info <be.info@dmirs.wa.gov.au> wrote:

Hope this helps.



Jessica Joseph | Customer Contact Officer

Safety, Building and Energy Contact Centre | Customer Information, Regulation and Safety.

Department of Mines, Industry Regulation and Safety

Level 1, Mason Bird Building, 303 Sevenoaks Street, CANNINGTON WA 6107

Locked Bag 100, EAST PERTH, WA 6892

Building & Energy: 1300 489 099 or +61 8 6251 2917 | [be.info@dmirs.wa.gov.au](mailto:be.info@dmirs.wa.gov.au)

WorkSafe: 1300 30 78 77 or +61 8 6251 2200 | [wscallcentre@dmirs.wa.gov.au](mailto:wscallcentre@dmirs.wa.gov.au)

[www.dmirs.wa.gov.au](http://www.dmirs.wa.gov.au)

ent or body. In order to be  
st for us or wish to lodge a